
Brown County Reforestation Camp Campground


CONSTRUCTION PLANS


JOB NUMBER 13744

PORTIONS OF SECTION 9,

PARCEL ID: SU-156, 157, 159, 160, 161, 162







INDEX OF SHEETS C200 C201 UTILITY PLAN PLAN & PROFILE: CO 1 - BATHHOUSE C202 PLAN & PROFILE: CO 1 - CO 8 PLAN & PROFILE: LIFT STATION — CO 10 PLAN & PROFILE: DUMP STATION — CO 15 C203 C204 C300 CONSTRUCTION DETAILS C301 CONSTRUCTION DETAILS C302 CONSTRUCTION DETAILS C303 C304 C305 BATHHOUSE DETAILS DUMP STATION DETAILS SEPTIC TANK AT EAST BATHHOUSE DETAILS C306 STORM POND DETAILS PRELIMINARY BRIDGE DESIGN PRELIMINARY BRIDGE DESIGN C400

ELECTRICAL SITE PLAN

ELECTRICAL RISER DIAGRAM

LEGEND

- PROPOSED SANITARY CLEANOUT - PROPOSED SEWER RISER


- PROPOSED WATER / ELECTRIC RISER - PROPOSED BALL VALVE

- PROPOSED YARD HYDRANT

- PROPOSED FORCEMAIN - PROPOSED SANITARY SEWER LATERAL

- SILT FENCE


- STONE RIPRAP - STANDARD BIO-DEGRADABLE EROSION MATTING





C401


E1


ounty Brown























2. ANY SOIL STOCKPILE THAT REMAINS FOR MORE THAN 7 DAYS SHALL BE COVERED OR TREATED WITH STABILIZATION PRACTICES SUCH AS TEMPORARY OR PERMANENT SEEDING AND MULCHING. SEEDING SHALL FOLLOW THE REQUIREMENTS OF WDNR TECHNICAL STANDARDS 1058 AND 1059 AND WIS. DOT STANDARD

3. A MINIMUM OF 4 TO 6 INCHES OF TOPSOIL MUST BE APPLIED TO ALL AREAS TO BE SEEDED OR SODDED ACCORDING TO WDNR TECHNICAL STANDARD 1059.

4. ALL OFF-SITE SEDIMENT DEPOSITS OCCURRING AS A RESULT OF CONSTRUCTION WORK OR STORM EVENT SHALL BE CLEANED UP BY THE END OF EACH DAY. FLUSHING SHALL NOT BE ALLOWED. IMPLEMENT TEMPORARY GRADING PRACTICES AS DESCRIBED IN WDNR TECHNICAL STANDARDS 1066 AND 1067 TO PREVENT SEDIMENT FROM LEAVING THE SITE.

5. ALL DISTURBED AREAS SHALL BE TREATED WITH STABILIZATION MEASURES, AS SPECIFIED, WITHIN 3 WORKING DAYS OF FINAL GRADING.

6. ANY SOIL EROSION THAT OCCURS AFTER FINAL GRADING AND/OR THE APPLICATION OF STABILIZATION MEASURES MUST BE REPAIRED AND STABILIZATION WORK REDONE.

7. TREAT ANY DISTURBED AREA THAT REMAINS INACTIVE FOR GREATER THAN 7 WORKING DAYS OR WHERE GRADING WORK EXTENDS BEYOND THE PERMANENT SEEDING DEADLINES WITH TEMPORARY BEST MANAGEMENT PRACTICES SUCH AS LAND APPLICATION OF ANIONIC POLYACRYLAMIDE. STRAW BALES. SILT FENCE, MULCHING, TEMPORARY SEEDING, AND SEDIMENT TRAPS AS RESPECTIVELY REQUIRED BY WONR TECHNICAL STANDARDS 1050, 1055, 1056, 1058, 1059, AND 1063.

8. ALL TEMPORARY BEST MANAGEMENT PRACTICES SHALL BE MAINTAINED UNTIL THE SITE IS STABILIZED.

9. WIND EROSION SHALL BE KEPT TO A MINIMUM DURING CONSTRUCTION. WATERING, MULCHING, OR A TACKING AGENT MAY NEED TO BE UTILIZED TO PROTECT NEARBY RESIDENTS AND WATER RESOURCES. DUST CONTROL MEASURES SHALL BE IMPLEMENTED ACCORDING TO WDNR TECHNICAL STANDARD 1068.

10. WHEN THE DISTURBED AREA HAS BEEN STABILIZED BY PERMANENT VEGETATION OR OTHER MEANS, TEMPORARY BEST MANAGEMENT PRACTICES SUCH AS SILT FENCE, STRAW BALES, AND SEDIMENT TRAPS

11. ALL REMAINING TOPSOIL STOCKPILES SHALL BE SEEDED OR HAULED OFF-SITE WITHIN 60 DAYS OF CONSTRUCTION COMPLETION.

12. <u>WINTER STABILIZATION</u>: ALL AREAS REQUIRING SEED AFTER OCTOBER 15TH SHALL BE STABILIZED BY AN APPROVED WINTER STABILIZATION METHOD. THE RECOMMENDED METHOD IS UTILIZING A HYDROSEEDER CONTAINING ADEQUATE TACKIFIER POLYMER MIXED WITH WINTER WHEAT OR RYE SEED. ANOTHER ACCEPTABLE EROSION CONTROL METHOD IS THE LAND APPLICATION OF ANIONIC POLYACRYLAMIDE IN CONFORMANCE WITH WDNR TECHNICAL

13.ADDITIONAL EROSION CONTROL METHODS SUCH AS SILT FENCE, BALE CHECKS, EROSION MAT, (ABOVE AND BEYOND THE QUANTITIES LISTED IN THE BID PROPOSAL) AS NEEDED TO PREVENT WASHOUT OR SILT TRANSFER PROBLEMS WITHIN THE CONSTRUCTION AREA OR DOWNSTREAM SHALL BE CONSIDERED INCIDENTAL TO THIS PROPOSAL.

Stabilization Specifications

(REFER TO EROSION CONTROL PLAN FOR APPLICABLE AREAS)

MULCH: MATERIAL SHALL CONSIST OF ANY STRAW, HAY, WOOD EXCELSIOR FIBER OR OTHER SUITABLE MATERIAL OF A SIMILAR NATURE WHICH IS SUBSTANTIALLY FREE OF NOXIOUS WEED SEEDS AND OBJECTIONABLE FOREIGN MATTER. MULCH SHALL CONFORM TO WDNR TECHNICAL STANDARD 1058.

STANDARD BIODEGRADABLE MAT: CLASS 1, TYPE A, AS LISTED IN THE LATEST EDITION OF THE WIS. DOT EROSION CONTROL P.A.L. PRODUCTS WITH UV DEGRADABLE NETTING SHALL NOT BE INSTALLED AFTER SEPTEMBER 1ST. TYPE B MAT MAY BE USED IN REPLACEMENT FOR TYPE A MAT AT THE OPTION OF THE CONTRACTOR WITH NO ADDITIONAL COST TO THE OWNER. EROSION MAT SHALL ALSO MEET THE REQUIREMENTS OF WONR TECHNICAL STANDARD 1053.

HIGH VELOCITY EROSION MAT: CLASS 1, TYPE B, AS LISTED IN THE LATEST EDITION OF THE WIS. DOT EROSION CONTROL P.A.L. PRODUCTS WITH UV DEGRADABLE NETTING SHALL NOT BE INSTALLED AFTER SEPTEMBER 1ST. EROSION MAT SHALL ALSO MEET THE REQUIREMENTS OF WDNR TECHNICAL STANDARD 1053.

STAPLES: USE U-SHAPED STAPLES NO. 11 GAUGE OR HEAVIER STEEL WIRE OR OTHER APPROVED MATERIALS, WITH A WIDTH OF ONE TO TWO INCHES, AND A LENGTH NOT LESS THAN 6 INCHES FOR FIRM SOILS AND NOT LESS THAN 12 INCHES

INSTALLATION: ALL EROSION MATTING SHALL BE INSTALLED WITH DOWNSLOPE EDGE BURIED OR OVERLAPPED A MINIMUM OF 3 INCHES BY UPSLOPE MATTING TO PREVENT UNDERFLOWS.

RIP-RAP: 4-12" ROCK, 50% > 6", 10-20% < 2" (OVER 8 OZ. GEOTEXTILE) DECORATIVE STONE MAY BE USED AS LONG

WIS DOT Standard Specifications Section 630 Permanent Seed Mixtures

		_				
SPECIES	% MINIMUM PURITY	% MINIMUM GERMINATION	MIXTURE PROPORTIONS in percent			
SI EGIES	76 WINNINGWIT CIVITI	76 WINNING OLIVINATION	NO. 10	NO. 20	NO. 30	NO. 40
KENTUCKY BLUEGRASS	98	85	40	6	10	35
RED FESCUE	97	85	25		30	20
HARD FESCUE	97	85		24	25	20
TALL FESCUE	98	85		40		
SALT GRASS	98	85			10	
REDTOP	92	85	5			
PERENNIAL RYEGRASS	97	90	20	30		
IMPROVED FINE PERENNIAL RYEGRASS	96	85			15	25
WHITE CLOVER	95	90	10			
BIRDSFOOT TREFOIL	95	80			10	

1. USE SEED MIXTURE NO. 10 WHERE AVERAGE LOAM, HEAVY CLAY, OR MOIST SOILS PREDOMINATE. 2. USE SEED MIXTURE NO. 20 WHERE LIGHT, DRY, WELL-DRAINED, SANDY, OR GRAVELLY SOILS PREDOMINATE AND FOR ALL HIGH

CUT AND FILL SLOPES GENERALLY EXCEEDING 6 TO 8 FEET (1.8 TO 2.4 m). 3. USE SEED MIXTURE NO. 10 OR NO. 20 ON ALL DITCHES, INSLOPES, MEDIAN AREAS, AND LOW FILLS, EXCEPT WHERE USING

4. USE SEED MIXTURE NO. 30 FOR MEDIANS AND ON SLOPES OR DITCHES GENERALLY WITHIN 15 FEET (4.5 m) OF THE SHOULDER WHERE A SALT-TOLERANT TURF IS PREFERRED.

5. USE SEED MIXTURE NO. 40 IN URBAN OR OTHER AREAS WHERE A LAWN TYPE TURF IS PREFERRED.

USE THE FOLLOWING SOWING RATE FOR SEEDS IN POUNDS (kg) PER 1000 SQUARE FEET (100 SQUARE METERS) OF AREA:

- SEED MIXTURE NO. 10 AT 1.5 POUNDS (0.7 kg)

- SEED MIXTURE NO. 20 AT 3.0 POUNDS (1.5 kg)

- SEED MIXTURE NO. 30 AT 2.0 POUNDS (1.0 kg) - SEED MIXTURE NO. 40 AT 2.0 POUNDS (1.0 kg)

NOTE: REFER TO LANDSCAPE PLAN FOR AREAS REQUIRING PRAIRIE GRASS PLANTINGS.

Procedures of Construction

1. INSTALL EROSION CONTROL MEASURES PER PHASE OF CONSTRUCITON WORK PER PLAN.

2. STRIP TOPSOIL IN STORMWATER POND PER PHASE AND STOCKPILE.

3. EXCAVATE STORMWATER POND, INSTALL LINERS AND OUTLET STRUCTURES PER PHASE.

4. UTILIZE WET DETENTION PONDS AS SEDIMENT TRAP DURING CONSTRUCTION.

5. INSTALL SEWER, WATER, & UTILITIES PER PHASE.

6. STRIP TOPSOIL IN REMAINING AREAS AND STOCKPILE.

7. GRADE SITE TO SUB GRADE PER PHASE. 8. PLACE GRAVEL IN ENTRANCE DRIVE, ACCESS DRIVES, RV PADS, AND PARKING LOTS PER

9. TOPSOIL, SEED, FERTILIZE AND MULCH ALL DISTURBED AREAS.

10. INSTALL STABILIZATION MEASURES (EROSION MATTING PER PHASE OF PLAN).

11. EXCAVATE SEDIMENT FROM CONSTRUCTION SITE RUNOFF OUT OF DETENTION PONDS TO MATCH PLAN GRADE AFTER AT LEAST 75% OF THE PERMANENT VEGETATION HAS BEEN ESTABLISHED. (AS NEEDED)

12. TOPSOIL, SEED, FERTILIZE AND MULCH ALL REDISTURBED AREAS.

13. REMOVE EROSION CONTROL MEASURES WHEN GRASS HAS BEEN WELL ESTABLISHED.

Site Dewatering (IF NEEDED)

1. DEWATERING FOR POND & UTILITY CONSTRUCTION SHALL CONFORM TO REQUIREMENTS SET FORTH IN WDNR TECHNICAL STANDARD 1061.

2. THE CONTRACTOR HAS THE OPTION TO UTILIZE WONR APPROVED METHODS INCLUDING:

- GEOTEXTILE BAGS (SEE TECHNICAL STANDARD 1061) - SEDIMENT TRAPS (SEE TECHNICAL STANDARD 1063)

- SEDIMENT BASINS (SEE TECHNICAL STANDARD 1064) 3. CONTRACTOR HAS OPTION TO UTILIZE STORM PONDS CONSTRUCTED ON THIS SITE AS SEDIMENT

4. CONTRACTOR SHALL LIMIT PUMP RATE TO BE LESS THAN 70 G.P.M. TO PREVENT NEED FOR WDNR

5. IN NO EVENT SHALL UNTREATED DISCHARGE BE ALLOWED TO FLOW DIRECTLY INTO WETLANDS OR

Temporary Seeding

SPECIES	% MINIMUM PURITY	% MINIMUM GERMINATION
ANNUAL OATS	98	90
AGRICULTURAL RYE	97	85
WINTER WHEAT	95	90
ANNUAL RYEGRASS	97	90

USE OATS IN SPRING AND SUMMER PLANTINGS. 2. USE WINTER WHEAT OR RYE FOR FALL PLANTINGS STARTED AFTER SEPTEMBER 3. APPLY TEMPORARY SEEDING AT 3 POUNDS PER 1000 SQUARE FEET OF AREA, EXCEPT ANNUAL RYEGRASS WHICH MAY BE APPLIED AT 2 POUNDS PER 1000 SQUARE FEET OF AREA.

Wet Seed Mix (IN BASE AND SIDE SLOPES OF DETENTION POND AREAS


rone areas)	
Plant Type	PLS oz/acre
Grass	2.0
Grass	2.0
Grass	8.0
Grass	16.0
Sedge	1.0
Sedge	2.0
Forb	1.0
Forb	2.0
Forb	1.0
Forb	2.0
Forb	2.0
	Plant Type Grass Grass Grass Grass Sedge Sedge Forb Forb Forb Forb

(OR EQUIVALENT)

Dumpster Enclosure Example



Swale Detail NO SCALE



- WHERE SPECIFIED, EROSION MATTING, STAKED SOD OR RIP-RAP SHALL BE A MINIMUM OF 6' WIDE CENTERED IN THE SWALE


Bathhouse Example

NO SCALE

SEE SHEET C303 FOR ADDITIONAL BATHHOUSE DETAILS




CONTRACTOR IS RESPONSIBLE FOR MAINTENANCE AND DOCUMENTATION OF EROSION CONTROL MEASURES THROUGHOUT CONSTRUCTION PHASE. OWNER IS RESPONSIBLE FOR MAINTENANCE AFTER CONTRACTOR LEAVES THE SITE.





(ALL DOWNSLOPE ENDS OF CULVERTS)


Temporary Stone Tracking Pad Detail




Silt Fence Detail NO SCALE










Entrance Driveway Detail A-A NO SCALE



Access Drives - RV Pad - Parking Lot & Dumpster Pad Cross-Section


NOTE:

SET FINISHED C/L GRADE 4"± ABOVE EXISTING GRADE TO CREATE CROWN.

ALL FILLING AND GRADING TO STAY OUTSIDE OF WETLAND DELINEATED ARES, SEE PLAN VIEW FOR


NARROW DRIVEWAY IN SELECT AREAS TO MIN. 16' WIDTH AS NEEDED TO PREVENT WETLAND IMPACT NO FILLING NOR GRADING WITHIN WETLANDS PERMITTED.

NO SCALE



ALL BACKFILL/SUBGRADE IN EXISTING OR PROPOSED ROADS SHALL BE COMPACTED QUARRY WASH SPECIFICATIONS:
COVER MATERIAL SHALL CONSIST OF CRUSHED LIMESTONE SCREENINGS AND
CONFORM TO THE FOLLOWING GRADATION REQUIREMENTS: PERCENTAGE PASSING SIEVE SIZES BY WEIGHT NO. 40 NO. 100 NO. 200 65-85 25-40 8-25

Concrete Sidewalk Detail NO SCALE



NOTES

1. COMPACT SUBGRADE TO 95% STANDARD PROCTOR. SUBGRADE TO BE INSPECTED BY PROJECT FOREMAN PRIOR TO PLACEMENT OF AGGREGATE BASE COURSE SPECIFICATIONS


CONCRETE PAVEMENT CONSTRUCTION SHALL BE IN ACCORDANCE WITH WISCONSIN DOT FDM

CONCRETE SHALL BE 4,000 PSI MINIMUM

CONCRETE SHALL RECEIVE A BROOMED FINISH

Bro

Culvert & Storm Sewer Bedding Detail NO SCALE




NOTE:

3" OF ADDITIONAL CRUSHED STONE REQUIRED IN WET TRENCH AT NO ADDITIONAL COST.

BURIED DEPTHS VARY, SEE GRADING PLAN FOR CULVERT/STORMSEWER INVERTS AND DEPTHS.

Standard Trench Section NO SCALE




NOTE:

• BURIED DEPTHS VARY, SEE UTILITY PLANS AND PROFILES FOR SEWER AND WATER DEPTHS.


• WATER SERVICE TO MAINTAIN 3' COVER WHERE NOT IN THE SAME TRENCH AS SEWER.


• CAMPGROUND IS FOR SUMMER USE ONLY AND WILL BE WINTERIZED AT END OF SEASON, THEREFORE PROJECT SITE EXEMPT FROM MINIMUM SEWER DEPTH PER SPS 382.30(11)(c)(2)(e). WHERE WATER SERVICE CROSSES SANITARY SEWER, WATER PIPING TO BE INSTALLED AT LEAST 12—INCHES ABOVE TOP OF SEWER. SEE UTILITY PLANS AND PROFILES FOR LOCATIONS. · TRACER WIRE SHALL BE INSTALLED FOR ALL NON-METALLIC SEWER AND WATER PIPING. WIRE SHALL BE INSTALLED DIRECTLY ABOVE THE TOP OF PIPE AND WITHIN 6-INCHES OF THE PIPE. WHERE SEWER AND WATER PIPING SHARE A COMMON TRENCH, TRACER WIRE NEED ONLY BE · ALL SEWER AND WATER SYSTEMS MATERIAL SHALL BE IN ACCORDANCE WITH SPS 384.

Watermain Ball Valve Typical Detail NO SCALE



Lift Station Detail (Duplex Grinder) NO SCALE






LATERALS IN = 635.00ALARM = 634.75 $2.5' = 940 \text{ GALLONS } \pm$ 8QRS BOOT <u>PUMP OFF = 632.00</u> 5" THICK PRECAST CONCRETE STRUCTURE 631.00

> $\frac{\text{PUMP DESIGN}}{\text{PROPOSED FLOW}} = 30 \text{ GPM}$ 2"ø FORCE MAIN LENGTH MAX. = 830' ELEVATION AT SETTLING TANK = 652.00PUMP OFF AT LIFT STATION = 632.00ELEV. HEAD = 652.00 - 632.00 = 20.00 FT 2"ø AT 30 GPM FRICTION HEAD = 830' x 1.54 FT/100 FT = 12.78 FT FITTING, ETC. = 5.00 FTTDH = 37.78 FTMINIMUM REQUIRED: DUPLEX GRINDER PUMPS RATED AT 30 GPM @ 37.78 FT TDH SELECT LSG200, 2HP, SINGLE PHASE GRINDER PUMPS RATED AT 30 GMP @ APPROX. 75' TDH

DUPLEX GRINDER PUMPS-

 CONTRACTOR TO PROVIDE A TEE AND THREADED CAP IN DISCHARGE LINE OR SOME OTHER METHOD TO ALLOW FORCEMAIN TO BE BLOWN OUT AT THE END OF THE SEASON.


Water Riser Detail NO SCALE




NOTE:


BACKFLOW PREVENTERS FOR WATER RISERS AND HOSE THREADED OUTLETS SHALL BE IN COMPLIANCE PER ASSE 1011.

Clean-out Detail NO SCALE





Yard Hydrant Detail




NOTE:


BACKFLOW PREVENTERS FOR WATER RISERS AND HOSE THREADED OUTLETS SHALL BE IN COMPLIANCE PER ASSE 1011.


YARD HYDRANT SHALL NOT HAVE UNDERGROUND WEEP HOLE FOR FROST—PROOF CAPABILITY, PER SPS 382.40(8)(e)2. CAMPSITE IS SEASONAL AND ALL WATER LINES SHALL BE BLOWN OUT AT THE END OF SEASON TO PREVENT WATER LINES FROM FREEZING.


• HYRDANT NOZZEL SHALL BE SIMILAR TO CAMPSITE RISERS OR EQUIVALENT PER

Brown











Typical Wet Pond Detail

(SEE GRADING PLAN AND ELEVATION TABLE FOR ELEVATIONS FOR EACH POND)




Typical Pond Outlet Structure Detail

(SEE GRADING PLAN AND ELEVATION TABLE FOR ELEVATIONS FOR EACH POND)



Typical Pond Spillway Detail


(SEE GRADING PLAN AND ELEVATION TABLE FOR ELEVATIONS FOR EACH POND)



Pond Elevations Table

		POND DETAILS		
	POND A	POND B	POND C	POND D
TOP OF BERM ELEVATION	638.00	640.00	641.00	638.00
SPILLWAY ELEVATION (TOP OF STONE)	637.50	639.50	640.50	637.50
PERMANENT POOL ELEVATION	636.00	638.00	638.00	636.00
SAFETY LEDGE TOP ELEVATION	635.5	637.5	637.5	635.5
SAFETY LEDGE BOTTOM ELEVATION	634.5	636.5	636.5	634.5
SEDIMENT EXCAVATION ELEVATION	633.00	635.00	635.00	633.00
POND BOTTOM ELEVATION	631.00	633.00	633.00	631.00
OUTLET STRUCTURE				
TOP OF RISER ELEVATION	637.25	639.25	639.90	637.25
ORIFICE INVERT ELEVATION	636.00	638.00	638.00	636.00
PIPE INLET INVERT ELEVAITON	636.00	638.00	638.00	636.00
PIPE OUTLET INVERT ELEVATION	635.93	637.95	637.87	635.96
PIPE LENGTH	27 L.F.	20 L.F.	50 L.F.	16 L.F.

Anti-Clog Cage Detail NO SCALE



SPECIFICATIONS: - EXTEND 3" OUT FROM ORIFICE - < 1/2" MAX. OPENINGS - USE SCREENING OVER CAGE OR SIMILAR - ATTACH CAGE TO CONCRETE RISER FACE USING MIN (4) 3/6" TAPCONS, OR SIM.

- DETAIL AS SHOWN ABOVE OR SIMILAR

Wet Pond Liner PER WET DETENTION POND DNR TECHNICAL STANDARD 1001

TYPE B LINERS — FOR SITES WITH MEDIIUM POTENTIAL FOR GROUNDWATER POLLUTION OR WHERE NEED FOR A FULL POOL LEVEL IS HIGH.

- THEY INCLUDE: ALL LINERS MEETING TYPE A CRITERIA
- POLY ETHYLENE POND LINER (PPL)

 1. CLAY LINER CRITERIA:
- A. 50% FINES (200 SIEVE) OR MORE.


 B. AN IN-PLACE HYDRAULIC CONDUCTIVITY OF


 1 x 10⁻⁶ CM./SEC. OR LESS.
- C. AVERAGE LIQUID LIMIT VALUE OF 16 OR GREATER, WITH NO VALUE LESS THAN
- D. AVERAGE PI OF 7 OR MORE WITH NO VALUES LESS THAN 14.
- E. CLAY COMPACTION AND DOCUMENTATION AS SPECIFIED IN NRCS WISCONSIN CONSTRUCTION
- SPECIFICATION 204, EARTHFULL FOR WASTE STORAGE FACILITES.


 F. MINIMUM THICKNESS OF TWO FEET.
- G. SPECIIFY METHOD FOR KEEPING THE POOL FULL OR USE OF COMPOSITE SOILS BELOW
- 2. HDPE LINER CRITERIA: A. MINIMUM THICKNESS SHALL BE 40 MILS.


HDPE LINER.

B. ALL OTHER CRITERIA SAME AS FOR TYPE A HDPE LINER. 3. PPL LINER CRITERIA: A. MINIMUM THICKNESS SHALL BE 30 MILS.
B. ALL OTHER CRITERIA SAME AS FOR TYPE A










NOTE: FINAL DESIGN PLANS SUPPLIED BY CONTECH PRIOR TO CONSTRUCTION


amp

Reforestation mpground

County R Camp

Brown







 ∞

 \supset

lоп

匠

 \Box

am


static

e

efo

Brown

ounty Can




BROWN COUNTY REFORE: 4418 REFORESTATION RO, SUAMICO, WI 54313

DATE: 06/16/20

DRAWN BY: KLP

CHECKED BY: BEC SHEET TITLE:

ELECTRICAL SITE PLAN



29 SPACE

PANEL SCHEDULE "A" VOLTAGE: 120/240 AMPERAGE: 200 MLO PHASE: 1						
NO.	DESCRIPTION	CKT. BRKR.	CKT. BRKR.	DESCRIPTION	NO.	
1	CAMPSITES 1, 2, 3	9ØA/2P	90A/2P	CAMPSITES 4, 5, 6	2	
3					4	
5	CAMPSITES 12, 13	60A/2P	60A/2P	SPARE	6	
٦					8	
9	LIFT STATION GRINDER PUMP	40A/2P		SPACE	10	
11				SPACE	12	
13	LIFT STATION GRINDER PUMP	40A/2P		SPACE	14	
15				SPACE	16	
٦٦	SPACE			SPACE	18	
19	SPACE			SPACE	20	
21	SPACE			5PACE	22	
23	SPACE			5PACE	24	
25	SPACE			SPACE	26	
27	SPACE			SPACE	28	
29	SPACE			SPACE	30	

	P	ANEL SCH	EDULE "E	AMPERAGE: 200 PHA9E: 1	
NO.	DESCRIPTION	CKT. BRKR.	CKT. BRKR.	DESCRIPTION	NO.
1	CAMPSITES 11, 14, 15, 16	125A/2P	125A/2P	CAMPSITES 7, 8, 9, 10	2
3					4
5	SPARE	60A/2P	60A/2P	SPARE	6
٦					8
9	SPACE			SPACE	10
11	SPACE			SPACE	12
13	SPACE			SPACE	14
15	SPACE			SPACE	16
ΙT	SPACE			SPACE	18
19	SPACE			SPACE	2Ø
21	SPACE			SPACE	22
23	SPACE			SPACE	24
25	SPACE			SPACE	26
27	SPACE			SPACE	28
29	SPACE			SPACE	3Ø

		PANEL SCH	EDULE "E	"	
NO.	DESCRIPTION	CKT. BRKR.	CKT. BRKR.	DESCRIPTION	NO.
1	SPARE	9ØA/2P	9ØA/2P	CAMPSITES 35, 36, 37	2
3					4
5	SPARE	60A/2P	60A/2P	SPARE	6
٦					8
9	SPACE			5PACE	10
11	SPACE			5PACE	12
13	SPACE			SPACE	14
15	SPACE			SPACE	16
ΙT	SPACE			6PACE	18
19	SPACE			5PACE	2Ø
21	SPACE			5PACE	22
23	SPACE			5PACE	24
25	SPACE			5PACE	26
27	SPACE			SPACE	28
29	SPACE			SPACE	3Ø

					10
	P,	ANEL SCH	EDULE "F	AMPERAGE: 200 PHASE: 1	MLO
NO.	DESCRIPTION	CKT. BRKR.	CKT. BRKR.	DESCRIPTION	NO.
1	CAMPSITES E4, E5, E6	90A/2P	90A/2P	CAMPSITES EI, E2, E3	2
3					4
5	ENTRY KIOSK	20A/IP	60A/2P	SPARE	6
٦	SPARE	60A/2P			8
9				5PACE	10
11	SPACE			5PACE	12
13	SPACE			SPACE	14
15	SPACE			SPACE	16
17	SPACE			5PACE	18
19	SPACE			5PACE	20
21	SPACE			SPACE	22
23	SPACE			SPACE	24
25	SPACE			6PACE	26
27	5PACE			SPACE	28
29	SPACE			SPACE	3Ø

	F	PANEL SCH	EDULE "C	VOLTAGE: 120/24 AMPERAGE: 200 PHASE: 1	
NO.	DESCRIPTION	CKT. BRKR.	CKT. BRKR.	DESCRIPTION	NO
1	CAMPSITES 18, 19, 25	9ØA/2P	9ØA/2P	CAMPSITES 17, 26, 27	2
3					4
5	SPARE	60A/2P	60A/2P	SPARE	6
٦					8
9	SPACE			SPACE	10
11	SPACE			SPACE	12
13	SPACE			SPACE	14
15	SPACE			SPACE	16
17	SPACE			SPACE	18
19	SPACE			SPACE	20
21	SPACE			SPACE	22
23	SPACE			5PACE	24
25	SPACE			SPACE	26
27	SPACE			5PACE	28

SPACE

30

PANEL SCHEDULE "D" VOLTAGE: 120/240 AMPERAGE: 200 MLO PHASE: 1						
NO.	DESCRIPTION	CKT. BRKR.	CKT. BRKR.	DESCRIPTION	NO.	
1	CAMPSITES 20, 21, 22	90A/2P	90A/2P	CAMPSITES 23, 24, 28	2	
3					4	
5	SPARE	60A/2P	60A/2P	SPARE	6	
٦					8	
9	SPACE			SPACE	10	
11	SPACE			SPACE	12	
13	SPACE			SPACE	14	
15	SPACE			SPACE	16	
ΙT	SPACE			SPACE	18	
19	SPACE			SPACE	20	
21	SPACE			SPACE	22	
23	SPACE			SPACE	24	
25	SPACE			SPACE	26	
27	SPACE			SPACE	28	
29	SPACE			SPACE	3Ø	

REVISIONS

NO.

BY DATE
1500 TEMPLE MORE LANI
GREEN BAY, WI 54313
TELEPHONE 920-490-941
CELL 920-819-1075
ELECTRICAL DESIGN/CONSULTINK

BROWN COUNTY REFORESTATIC 4418 REFORESTATION ROAD SUAMICO, WI 54313

DATE: 12/10/20

SCALE: NTS

DRAWN BY: KLP

CHECKED BY: BEC

SHEET TITLE:

ELECTRICAL

RISER DIAGRAM

F2

SHEET NO.